

SIMATIC S7-300 CPU 317-2 PN/DP, Central processing unit with 1 MB work memory, 1st interface MPI/DP 12 Mbit/s, 2nd interface Ethernet PROFINET, with 2-port switch, Micro Memory Card required



General information	
HW functional status	01
Firmware version	V3.2
Engineering with	
<ul style="list-style-type: none"> <li>Programming package</li> </ul>	STEP 7 V5.5 or higher
Supply voltage	
Rated value (DC)	
<ul style="list-style-type: none"> <li>24 V DC</li> </ul>	Yes
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
<ul style="list-style-type: none"> <li>Mains/voltage failure stored energy time</li> <li>Repeat rate, min.</li> </ul>	5 ms 1 s
Input current	
Current consumption (rated value)	750 mA
Current consumption (in no-load operation), typ.	150 mA

Inrush current, typ.	4 A
$I^2t$	1 A <sup>2</sup> ·s
<b>Power loss</b>	
Power loss, typ.	4.65 W
<b>Memory</b>	
<b>Work memory</b>	
<ul style="list-style-type: none"> <li>integrated</li> </ul>	1 024 kbyte
<ul style="list-style-type: none"> <li>expandable</li> </ul>	No
<ul style="list-style-type: none"> <li>Size of retentive memory for retentive data blocks</li> </ul>	256 kbyte
<b>Load memory</b>	
<ul style="list-style-type: none"> <li>Plug-in (MMC)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>Plug-in (MMC), max.</li> </ul>	8 Mbyte
<ul style="list-style-type: none"> <li>Data management on MMC (after last programming), min.</li> </ul>	10 y
<b>Backup</b>	
<ul style="list-style-type: none"> <li>present</li> </ul>	Yes; Guaranteed by MMC (maintenance-free)
<ul style="list-style-type: none"> <li>without battery</li> </ul>	Yes; Program and data
<b>CPU processing times</b>	
for bit operations, typ.	0.025 μs
for word operations, typ.	0.03 μs
for fixed point arithmetic, typ.	0.04 μs
for floating point arithmetic, typ.	0.16 μs
<b>CPU-blocks</b>	
Number of blocks (total)	2 048; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used.
<b>DB</b>	
<ul style="list-style-type: none"> <li>Number, max.</li> </ul>	2 048; Number range: 1 to 16000
<ul style="list-style-type: none"> <li>Size, max.</li> </ul>	64 kbyte
<b>FB</b>	
<ul style="list-style-type: none"> <li>Number, max.</li> </ul>	2 048; Number range: 0 to 7999
<ul style="list-style-type: none"> <li>Size, max.</li> </ul>	64 kbyte
<b>FC</b>	
<ul style="list-style-type: none"> <li>Number, max.</li> </ul>	2 048; Number range: 0 to 7999
<ul style="list-style-type: none"> <li>Size, max.</li> </ul>	64 kbyte
<b>OB</b>	
<ul style="list-style-type: none"> <li>Size, max.</li> </ul>	64 kbyte
<ul style="list-style-type: none"> <li>Number of free cycle OBs</li> </ul>	1; OB 1
<ul style="list-style-type: none"> <li>Number of time alarm OBs</li> </ul>	1; OB 10
<ul style="list-style-type: none"> <li>Number of delay alarm OBs</li> </ul>	2; OB 20, 21
<ul style="list-style-type: none"> <li>Number of cyclic interrupt OBs</li> </ul>	4; OB 32, 33, 34, 35

- Number of process alarm OBs 1; OB 40
- Number of DPV1 alarm OBs 3; OB 55, 56, 57
- Number of isochronous mode OBs 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously)
- Number of startup OBs 1; OB 100
- Number of asynchronous error OBs 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO)
- Number of synchronous error OBs 2; OB 121, 122

#### Nesting depth

- per priority class 16
- additional within an error OB 4

### Counters, timers and their retentivity

#### S7 counter

- Number 512

#### Retentivity

- adjustable Yes
- lower limit 0
- upper limit 511
- preset Z 0 to Z 7

#### Counting range

- adjustable Yes
- lower limit 0
- upper limit 999

#### IEC counter

- present Yes
- Type SFB
- Number Unlimited (limited only by RAM capacity)

#### S7 times

- Number 512

#### Retentivity

- adjustable Yes
- lower limit 0
- upper limit 511
- preset No retentivity

#### Time range

- lower limit 10 ms
- upper limit 9 990 s

#### IEC timer

- present Yes
- Type SFB
- Number Unlimited (limited only by RAM capacity)

### Data areas and their retentivity

retentive data area in total	All, max. 256 KB
<b>Flag</b>	
• Number, max.	4 096 byte
• Retentivity available	Yes; From MB 0 to MB 4095
• Retentivity preset	MB 0 to MB 15
• Number of clock memories	8; 1 memory byte
<b>Data blocks</b>	
• Retentivity adjustable	Yes; via non-retain property on DB
• Retentivity preset	Yes
<b>Local data</b>	
• per priority class, max.	32 768 byte; Max. 2048 bytes per block
<b>Address area</b>	
<b>I/O address area</b>	
• Inputs	8 192 byte
• Outputs	8 192 byte
<b>of which distributed</b>	
— Inputs	8 192 byte
— Outputs	8 192 byte
<b>Process image</b>	
• Inputs	8 192 byte
• Outputs	8 192 byte
• Inputs, adjustable	8 192 byte
• Outputs, adjustable	8 192 byte
• Inputs, default	256 byte
• Outputs, default	256 byte
<b>Subprocess images</b>	
• Number of subprocess images, max.	1; With PROFINET IO, the length of the user data is limited to 1600 bytes
<b>Digital channels</b>	
• Inputs	65 536
— of which central	1 024
• Outputs	65 536
— of which central	1 024
<b>Analog channels</b>	
• Inputs	4 096
— of which central	256
• Outputs	4 096
— of which central	256
<b>Hardware configuration</b>	
Number of expansion units, max.	3
<b>Number of DP masters</b>	

• integrated	1
• via CP	4
<b>Number of operable FMs and CPs (recommended)</b>	
• FM	8
• CP, PtP	8
• CP, LAN	10
<b>Rack</b>	
• Racks, max.	4
• Modules per rack, max.	8

### Time of day

<b>Clock</b>	
• Hardware clock (real-time)	Yes
• retentive and synchronizable	Yes
• Backup time	6 wk; At 40 °C ambient temperature
• Deviation per day, max.	10 s; Typ.: 2 s
• Behavior of the clock following POWER-ON	Clock continues running after POWER OFF
• Behavior of the clock following expiry of backup period	Clock continues to run with the time at which the power failure occurred

<b>Operating hours counter</b>	
• Number	4
• Number/Number range	0 to 3
• Range of values	0 to 2 <sup>31</sup> hours (when using SFC 101)
• Granularity	1 h
• retentive	Yes; Must be restarted at each restart

<b>Clock synchronization</b>	
• supported	Yes
• to MPI, master	Yes
• to MPI, slave	Yes
• to DP, master	Yes; With DP slave only slave clock
• to DP, slave	Yes
• in AS, master	Yes
• in AS, slave	Yes
• on Ethernet via NTP	Yes; As client

<b>Digital inputs</b>	
Number of digital inputs	0

<b>Digital outputs</b>	
Number of digital outputs	0

<b>Analog inputs</b>	
Number of analog inputs	0

<b>Analog outputs</b>	
-----------------------	--

Number of analog outputs	0
--------------------------	---

## Interfaces

Number of industrial Ethernet interfaces	1; 2 ports (switch) RJ45
Number of PROFINET interfaces	1; 2 ports (switch) RJ45
Number of RS 485 interfaces	1; Combined MPI / PROFIBUS DP
Number of RS 422 interfaces	0

### 1. Interface

Interface type	Integrated RS 485 interface
Physics	RS 485
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	200 mA

#### Protocols

• MPI	Yes
• PROFIBUS DP master	Yes
• PROFIBUS DP slave	Yes
• Point-to-point connection	No

#### MPI

• Transmission rate, max.	12 Mbit/s
---------------------------	-----------

#### Services

— PG/OP communication	Yes
— Routing	Yes
— Global data communication	Yes
— S7 basic communication	Yes
— S7 communication	Yes
— S7 communication, as client	No; but via CP and loadable FB
— S7 communication, as server	Yes

#### PROFIBUS DP master

• Transmission rate, max.	12 Mbit/s
• Number of DP slaves, max.	124

#### Services

— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
— SYNC/FREEZE	Yes

— Activation/deactivation of DP slaves	Yes
— Number of DP slaves that can be simultaneously activated/deactivated, max.	8
— Direct data exchange (slave-to-slave communication)	Yes; As subscriber
— DPV1	Yes
<b>Address area</b>	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
<b>User data per DP slave</b>	
— Inputs, max.	244 byte
— Outputs, max.	244 byte
<b>PROFIBUS DP slave</b>	
• Transmission rate, max.	12 Mbit/s
• automatic baud rate search	Yes; only with passive interface
• Address area, max.	32
• User data per address area, max.	32 byte
<b>Services</b>	
— PG/OP communication	Yes
— Routing	Yes; Only with active interface
— Global data communication	No
— S7 basic communication	No
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes; Connection configured on one side only
— Direct data exchange (slave-to-slave communication)	Yes
— DPV1	No
<b>Transfer memory</b>	
— Inputs	244 byte
— Outputs	244 byte
<b>2. Interface</b>	
Interface type	PROFINET
Physics	Ethernet RJ45
Isolated	Yes
automatic detection of transmission rate	Yes; 10/100 Mbit/s
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes
<b>Interface types</b>	
• Number of ports	2
• integrated switch	Yes

Media redundancy	
• supported	Yes
• Switchover time on line break, typ.	200 ms; PROFINET MRP
• Number of stations in the ring, max.	50
Protocols	
• MPI	No
• PROFINET IO Controller	Yes; Also simultaneously with IO-Device functionality
• PROFINET IO Device	Yes; Also simultaneously with IO Controller functionality
• PROFINET CBA	Yes
• PROFIBUS DP master	No
• PROFIBUS DP slave	No
• Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
• Web server	Yes
PROFINET IO Controller	
• Transmission rate, max.	100 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; with loadable FBs, max. configurable connections: 16, max. number of instances: 32
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
— Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
— IRT	Yes
— Shared device	Yes
— Prioritized startup	Yes
— Number of IO devices with prioritized startup, max.	32
— Number of connectable IO Devices, max.	128
— Of which IO devices with IRT, max.	64
— of which in line, max.	64
— Number of IO Devices with IRT and the option "high flexibility"	128
— of which in line, max.	61
— Number of connectable IO Devices for RT, max.	128
— of which in line, max.	128
— Activation/deactivation of IO Devices	Yes
— Number of IO Devices that can be simultaneously activated/deactivated, max.	8
— IO Devices changing during operation (partner ports), supported	Yes
— Number of IO Devices per tool, max.	8



— Device replacement without swap medium	Yes
— Send cycles	250 µs, 500 µs, 1 ms; 2 ms, 4 ms (not in the case of IRT with "high flexibility" option)
— Updating time	250 µs to 512 ms (depending on the operating mode, see Manual "S7-300 CPU 31xC and CPU 31x, Technical Data" for more details)
<b>Address area</b>	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
— User data consistency, max.	1 024 byte
<b>PROFINET IO Device</b>	
<b>Services</b>	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; with loadable FBs, max. configurable connections: 16, max. number of instances: 32
— Isochronous mode	No
— Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
— IRT	Yes
— PROFINergy	Yes; With SFB 73 / 74 prepared for loadable PROFINergy standard FB for I-Device
— Shared device	Yes
— Number of IO Controllers with shared device, max.	2
<b>Transfer memory</b>	
— Inputs, max.	1 440 byte; Per IO Controller with shared device
— Outputs, max.	1 440 byte; Per IO Controller with shared device
<b>Submodules</b>	
— Number, max.	64
— User data per submodule, max.	1 024 byte
<b>PROFINET CBA</b>	
• acyclic transmission	Yes
• cyclic transmission	Yes
<b>Open IE communication</b>	
• Number of connections, max.	16
• Local port numbers used at the system end	0, 20, 21, 23, 25, 80, 102, 135, 161, 443, 8080, 34962, 34963, 34964, 65532, 65533, 65534, 65535
• Keep-alive function, supported	Yes
<b>Protocols</b>	
<b>Open IE communication</b>	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	16

— Data length for connection type 01H, max.	1 460 byte
— Data length for connection type 11H, max.	32 768 byte
— several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	16
— Data length, max.	32 768 byte
• UDP	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	16
— Data length, max.	1 472 byte
<b>Web server</b>	
• supported	Yes
• User-defined websites	Yes
• Number of HTTP clients	5
<b>Isochronous mode</b>	
Isochronous operation (application synchronized up to terminal)	Yes; Via PROFIBUS DP or PROFINET interface
<b>Communication functions</b>	
PG/OP communication	Yes
Data record routing	Yes
<b>Global data communication</b>	
• supported	Yes
• Number of GD loops, max.	8
• Number of GD packets, max.	8
• Number of GD packets, transmitter, max.	8
• Number of GD packets, receiver, max.	8
• Size of GD packets, max.	22 byte
• Size of GD packet (of which consistent), max.	22 byte
<b>S7 basic communication</b>	
• supported	Yes
• User data per job, max.	76 byte
• User data per job (of which consistent), max.	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)
<b>S7 communication</b>	
• supported	Yes
• as server	Yes
• as client	Yes; via integrated PROFINET interface and loadable FB or via CP and loadable FB
• User data per job, max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
<b>S5 compatible communication</b>	
• supported	Yes; via CP and loadable FC

PROFINET CBA (at set setpoint communication load)	
• Setpoint for the CPU communication load	50 %
• Number of remote interconnection partners	32
• Number of functions, master/slave	30
• Total of all master/slave connections	1 000
• Data length of all incoming connections master/slave, max.	4 000 byte
• Data length of all outgoing connections master/slave, max.	4 000 byte
• Number of device-internal and PROFIBUS interconnections	500
• Data length of device-internal und PROFIBUS interconnections, max.	4 000 byte
• Data length per connection, max.	1 400 byte
Remote interconnections with acyclic transmission	
— Sampling frequency: Sampling time, min.	500 ms
— Number of incoming interconnections	100
— Number of outgoing interconnections	100
— Data length of all incoming interconnections, max.	2 000 byte
— Data length of all outgoing interconnections, max.	2 000 byte
— Data length per connection, max.	1 400 byte
Remote interconnections with cyclic transmission	
— Transmission frequency: Transmission interval, min.	10 ms
— Number of incoming interconnections	200
— Number of outgoing interconnections	200
— Data length of all incoming interconnections, max.	2 000 byte
— Data length of all outgoing interconnections, max.	2 000 byte
— Data length per connection, max.	450 byte
HMI variables via PROFINET (acyclic)	
— Number of stations that can log on for HMI variables (PN OPC/iMap)	3; 2x PN OPC/1x iMap
— HMI variable updating	500 ms
— Number of HMI variables	200
— Data length of all HMI variables, max.	2 000 byte
PROFIBUS proxy functionality	
— supported	Yes
— Number of linked PROFIBUS devices	16
— Data length per connection, max.	240 byte; Slave-dependent

Number of connections	
• overall	32
• usable for PG communication	31
— reserved for PG communication	1
— adjustable for PG communication, min.	1
— adjustable for PG communication, max.	31
• usable for OP communication	31
— reserved for OP communication	1
— adjustable for OP communication, min.	1
— adjustable for OP communication, max.	31
• usable for S7 basic communication	30
— reserved for S7 basic communication	0
— adjustable for S7 basic communication, min.	0
— adjustable for S7 basic communication, max.	30
• usable for S7 communication	16
— reserved for S7 communication	0
— adjustable for S7 communication, min.	0
— adjustable for S7 communication, max.	16
• total number of instances, max.	32
• usable for routing	X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max.

S7 message functions	
Number of login stations for message functions, max.	32; Depending on the configured connections for PG/OP and S7 basic communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300

Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4
Status/control	
• Status/control variable	Yes
• Variables	Inputs, outputs, memory bits, DB, times, counters
• Number of variables, max.	30
— of which status variables, max.	30
— of which control variables, max.	14
Forcing	
• Forcing	Yes
• Forcing, variables	Inputs, outputs
• Number of variables, max.	10

Diagnostic buffer	
• present	Yes
• Number of entries, max.	500
— adjustable	No
— of which powerfail-proof	100; Only the last 100 entries are retained
• Number of entries readable in RUN, max.	499
— adjustable	Yes; From 10 to 499
— preset	10
Service data	
• can be read out	Yes
Ambient conditions	
Ambient temperature during operation	
• min.	0 °C
• max.	60 °C
Configuration	
Configuration software	
• STEP 7	Yes; V5.5 or higher
Programming	
• Command set	see instruction list
• Nesting levels	8
• System functions (SFC)	see instruction list
• System function blocks (SFB)	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
• User program protection/password protection	Yes
• Block encryption	Yes; With S7 block Privacy
Dimensions	
Width	40 mm
Height	125 mm
Depth	130 mm
Weights	
Weight, approx.	340 g

last modified:

08/13/2018